



Calculation Summary				
Scene:				
Label	CalcType	Avg	Min/Avg	Min/Max
03 Mod Court 01 PPA	Illuminance	509.64	0.62	0.45
03 Mod Court 02 PPA	Illuminance	527.46	0.61	0.45

THE FOLLOWING LIGHTING CALCULATIONS ARE COMPLYING WITH AS 2560.2 TABLE 2.11.1 LIGHTING FOR OUTDOOR TENNIS COURTS

LEVEL OF APPLICATION - CLUB COMPETITION

PPA AVERAGE HORIZONTAL ILLUMINANCE = 350 LUX  
 MINIMUM UNIFORMITY = 0.6 (U1) 0.4 (U2)

MAXIMUM GLARE RATING = 50

NOTES:  
 LIGHTING DESIGN IS BASED ON THE INFORMATION SUPPLIED BY THE CLIENT

Buckford Illumination Group Pty Ltd 8/34 Wirraway Drive, Port Melbourne, Victoria 3207 Australia www.buckford.com.au		
PROJECT NAME: I0047 - Gungahlin Tennis Facility REV1		
LAYOUT VIEW: MOD COURTS RESULTS		
SALES ENGINEER: BN		
LIGHTING DESIGNER: AW		
PRINT SIZE: A3	PRINTED DATE: 07/11/2023	