



**NOTES:**

1. DRAWING TO BE READ IN CONJUNCTION WITH C.81, C.82, C.83 & C.84.
2. CAR PARK SPATIAL REVIEWS HAVE BEEN UNDERTAKEN ACCORDING TO THE DESIGN REQUIREMENTS OUTLINED IN AS2890.1:2004 - PART 1: OFF-STREET CAR PARKING AND AS2890.6:2009 PART 6: OFF-STREET PARKING FOR PEOPLE WITH DISABILITIES.
3. B99 SWEEP PATHS ARE TO BE APPLIED TO CIRCULATION ROUTES AS PER AS2890.1.
4. B85 SWEEP PATHS ARE TO BE LIMITED TO CAR PARKING SPACES AND PARKING AISLES AS PER AS2890.1.



B99		B85	
	meters		meters
Width	: 1.94	Width	: 1.87
Track	: 1.84	Track	: 1.77
Lock to Lock Time	: 6.0	Lock to Lock Time	: 6.0
Steering Angle	: 33.9	Steering Angle	: 34.1



- CLASS 2 PARKING REQUIRES MINIMUM 5.8m AISLE WIDTH, NOT INCLUDING ANY ADDITIONAL CLEARANCE REQUIREMENTS OF AS2890.1.
- CLASS 2 PARKING GENERALLY APPLIES TO THE BASEMENT CAR PARKS.

**CLASS 2 CAR SPACE CLEARANCE ENVELOPE**  
1:50 @ A1

- CLASS 1A PARKING REQUIRES MINIMUM 5.8m AISLE WIDTH, NOT INCLUDING ANY ADDITIONAL CLEARANCE REQUIREMENTS OF AS2890.1.
- CLASS 2 PARKING APPLIES TO SOME CAR SPACES WITHIN THE BASEMENT CAR PARKS.

**CLASS 1A CAR SPACE CLEARANCE ENVELOPE**  
1:50 @ A1

- VDS' INTERPRETATION OF THE APPLICATION OF KEEP CLEAR ENVELOPES TO SMALL CARSPACES. NOT EXPLICITLY DESCRIBED IN AS2890.1.

**SMALL CAR SPACE CLEARANCE ENVELOPE**  
1:50 @ A1

**2.4.5.5 Other protective devices**

Protective devices shall be provided as necessary to protect parts of the building or other fixed objects or equipment from damage by vehicles. Such protection shall include devices to prevent vehicle encroachment into pedestrian ways, stairs, doorways, lifts and the like. Appropriately located bollards are suitable for these purposes. Protective devices shall be clearly visible to drivers when in their normal driving position.


NOTE: Design impact forces are given in AS/NZS 1170.1.

AS2890.1 EXTRACT - BOLLARD PROTECTION OF DOORS ETC  
NTS

DISCIPLINE:  
**CIVIL SERVICES**

REV	ISSUE	CHK'D	APP'D	DATE
1	PRELIMINARY	S.G.	S.G.	15/11/21
2	PRELIMINARY	S.G.	S.G.	01/12/21
3	PRELIMINARY	S.G.	S.G.	23/02/22
4	PRELIMINARY	S.G.	S.G.	02/03/22
5	PRELIMINARY	S.S.	S.S.	16/03/22
6	PRELIMINARY	S.G.	S.G.	18/08/22

ALL DRAWINGS ARE DESIGNED TO BE PRINTED AND READ IN COLOUR  
IT IS THE CONTRACTORS' RESPONSIBILITY TO PRINT DRAWINGS IN COLOUR TO AVOID ANY POTENTIAL DISCREPANCIES IF DRAWINGS ARE PRINTED IN BLACK AND WHITE.



Canberra - Ground floor, 20 Spongolite Street, Beard ACT 2620  
Melbourne - Level 22, 535 Bourke Street, Melbourne Vic 3000  
Tel: 02 6297 2785 Email: admin@vdsol.com.au ABN 45 151 340 788  
Fax: 02 6299 2316 Web: vdsol.com.au ACN 151 340 788

ARCHITECT

CLIENT

PROJECT  
**WESTON VILLAGE  
BLOCK 1 SECTION 82  
UNWIN STREET  
WESTON ACT**

DRAWING TITLE  
**CAR PARK SPATIAL REVIEW  
NOTES AND DETAILS PLAN**

ALL DIMENSIONS ARE TO BE VERIFIED ON SITE PRIOR TO COMMENCEMENT OF WORKS, ORDERING MATERIAL OR PRODUCING SHOP DRAWINGS.  
THE COPYRIGHT OF THIS DRAWING REMAINS WITH VITAL DESIGN SOLUTIONS PTY LTD.

JOB REFERENCE: **VS21063**  
DRAWING NUMBER: **C.80**

DESIGNED: S.GWYNNE  
DRAFTED: E.PEARSON

SCALE: **NTS**  
SCALE: NTS SIZE: A1

ISSUE: **NOT FOR CONSTRUCTION**  
REVISION: **6**