


KEYPLAN


NOTES

1. FOR LEGEND AND SYMBOLS REFER TO DRAWING E001.
2. ALL WORKS TO BE DONE IN ACCORDANCE TO AS/NZS 3000.
3. THIS DRAWING TO BE READ IN CONJUNCTION WITH ALL OTHER ELECTRICAL DRAWINGS AND THE SPECIFICATION.
4. COORDINATE FINAL LOCATIONS OF ALL ELECTRICAL EQUIPMENT WITH OTHER SERVICES ON SITE TO MECHANICAL, FIRE, HYDRAULICS AND ARCHITECTURAL SERVICES DRAWINGS AS NECESSARY.
5. PROVIDE COMBINED MCB AND 30MA RCD IN DISTRIBUTION BOARD FOR ALL GENERAL POWER SUB-CIRCUITS OF 20A OR LESS. BALANCE THE LOAD EQUALLY ACROSS ALL THREE PHASES.
6. PROVIDE POWER, DATA AND MATV OUTLET FOR TELEVISION SET.
7. WAP LOCATIONS ARE INDICATIVE ONLY. FINAL REQUIREMENTS TO BE CONFIRMED BY CONTRACTOR.
8. PROVIDE SINGLE DATA OUTLET IN CEILING FOR ALL EXTERNAL CCTV.
9. INFRASTRUCTURE CONNECTIVITY REQUIREMENTS FOR FUTURE PATIENT INFORMATION AND ENTERTAINMENT SYSTEM (PIES). FINAL REQUIREMENTS TO BE CONFIRMED.



GROUND LEVEL - PALM HUB POWER LAYOUT

1 : 100



GROUND LEVEL MEZZANINE - PALM HUB POWER LAYOUT

1 : 100

REV	DATE	BY	DESCRIPTION	CHK	APP
P4	07.07.2023	NM	100% PSP	JJ	HH
P3	28.04.2023	NM	80% PSP	JJ	HH
P2	03.03.2023	NM	50% PSP	SG	HH
P1	03.02.2023	MAN	DRAFT 50% PSP	SG	HH
DRAWING STATUS: PRELIMINARY					



Level 2, 121 Marcus Clarke Street, Canberra ACT 2600
Tel: +61 2 6201 9600 / GPO Box 1551
<http://www.wsp.com>

CLIENT:



ARCHITECT:



PROJECT:

WATSON HEALTH HUB

TITLE:

ELECTRICAL SERVICES
PALM HUB
POWER AND COMMUNICATION LAYOUT

SCALE @ A1:	CHECKED:	APPROVED:
1:100	JJ	HH
PROJECT NUMBER:	DRAWN:	DATE:
PS132290	MAN	JANUARY 2023
DRAWING No:		REV:
E200		P4
© WSP Australia Pty Ltd		