


LONGITUDINAL SECTION
EXISTING 500mm DIAMETER WATER MAIN
SCALE H 1:250, V 1:125

LEGEND

- POTHOLE NUMBER AT LOCATION (No. 5 SHOWN)
- EXISTING PIPE ROAD CROSSING

ANY ROAD CONSTRUCTION WORKS TO BE COMPLETED IN THE VICINITY OF ICON WATER ASSETS ARE TO BE CONSTRUCTED IN ACCORDANCE WITH ICON WATER REQUIREMENTS. MAXIMUM PLANT LOADING OF 13.0 TONNE DURING CONSTRUCTION WITH VIBRATION SETTINGS TURNED OFF TO MAINTAIN THE STRUCTURAL INTEGRITY OF THE PIPE AND INTEGRITY OF THE CEMENT MORTAR LINING

NOTE
FOR GENERAL NOTES AND LEGEND REFER SMEC DRAWING No. 3002750-WS-001



NO.	REVISION	DATE	ENG CHECKED	VERIFIED	DESIGN AUTH
F	ICON WATER RESUBMISSION	07.05.2024	A.L.	A.C.	
E	ICON WATER RESUBMISSION	30.11.2023	A.L.	A.C.	
D	ISSUE FOR APPROVAL	11.11.2022	A.L.	A.C.	
C	ISSUE FOR APPROVAL	16.09.2022	A.L.	A.C.	



Drawn: N. BROOKE-TAYLOR	Designed: M. HOSSEINI
Checked: A. CHANDRA	
Project Manager: T. VAN NIEKERK	
Contractor's Drawing No.: 3002750-WS-002	
Icon Water Consented:	
Icon Water Design Authority:	

WILLIAM HOVELL DRIVE DUPLICATION
EXISTING 500 DIA WATER MAIN ROAD CROSSING
GENERAL ARRANGEMENT PLAN & LONGITUDINAL SECTION

Scale: AS SHOWN	Date: DR	Sheet No.:
Project No.: AS SHOWN	Tender No.:	
A1		3002750-WS-002
		Rev F