



ANY ROAD CONSTRUCTION WORKS TO BE COMPLETED IN THE VICINITY OF ICON WATER ASSETS ARE TO BE CONSTRUCTED IN ACCORDANCE WITH ICON WATER REQUIREMENTS. MAXIMUM PLANT LOADING OF 13.0 TONNE DURING CONSTRUCTION WITH VIBRATION SETTINGS TURNED OFF TO MAINTAIN THE STRUCTURAL INTEGRITY OF THE PIPE AND INTEGRITY OF THE CEMENT MORTAR LINING

NOTE
FOR GENERAL NOTES AND LEGEND REFER SMEC DRAWING No. 3002750-WS-001

No.	REVISION	DATE	ENG CHECKED	VERIFIED	DESIGN AUTH
F	ICON WATER RESUBMISSION	07.05.2024	A.L.	A.C.	
E	ICON WATER RESUBMISSION	30.11.2023	A.L.	A.C.	
D	ISSUE FOR APPROVAL	11.11.2022	A.L.	A.C.	
C	ISSUE FOR APPROVAL	16.09.2022	A.L.	A.C.	

<p>ACT Government Transport Canberra and City Services</p>	<p>Member of the Surbana Jurong Group © ABN 47 085 475 149 LEVEL 9, 12 MOORE STREET CANBERRA CITY ACT 2601 AUSTRALIA SMEC PROJECT No 3002750</p>	<p>icon WATER</p>	Drawn: N. BROOKE-TAYLOR Checked: A. CHANDRA Project Manager: T. VAN NIEKERK Contractor's Drawing No.: 3002750-WS-003 Icon Water Consented: Icon Water Design Authority:	Designed: M. HOSSEINI Date: AS SHOWN Project No.: AS SHOWN Tender No.: DR	Scale: AS SHOWN Sheet No.: A1 3002750-WS-003 Rev F
			WILLIAM HOVELL DRIVE DUPLICATION EXISTING 900 DIA WATER MAIN ROAD CROSSING GENERAL ARRANGEMENT PLAN & LONGITUDINAL SECTION		