


REPLACE HYDRANT WITH EXTENDED RISER AND
NEW HYDRANT TO MATCH NEW SURFACE LEVEL.
WORKS TO BE UNDERTAKEN BY ICON WATER.

- LEGEND**
- POTHOLE NUMBER AT LOCATION (No. 5 SHOWN)
 - EXISTING PIPE ROAD CROSSING

ANY ROAD CONSTRUCTION WORKS TO BE COMPLETED IN THE VICINITY OF ICON WATER ASSETS ARE TO BE CONSTRUCTED IN ACCORDANCE WITH ICON WATER REQUIREMENTS. MAXIMUM PLANT LOADING OF 13.0 TONNE DURING CONSTRUCTION WITH VIBRATION SETTINGS TURNED OFF TO MAINTAIN THE STRUCTURAL INTEGRITY OF THE PIPE AND INTEGRITY OF THE CEMENT MORTAR LINING

PLAN
SCALE 1:250

NOTE
FOR GENERAL NOTES AND LEGEND REFER
SMC DRAWING No. 3002750-WS-001



DESIGN

No.	REVISION	DATE	ENG CHECKED	VERIFIED	DESIGN AUTH
B	ICON WATER RESUBMISSION	07.05.2024	A.L.	A.C.	
A	ICON WATER RESUBMISSION	30.11.2023	A.L.	A.C.	



Drawn:	N.BROOKE-TAYLOR	Designed:	M. HOSSEINI
Checked:	A.CHANDRA		
Project Manager:	T. VAN NIEKERK		
Contractor's Drawing No.:	3002750-WS-004		
Icon Water Consented:			
Icon Water Design Authority:			

WILLIAM HOVELL DRIVE DUPLICATION
EXISTING 100 DIA WATER MAIN ROAD CROSSING
GENERAL ARRANGEMENT PLAN

Scale:	AS SHOWN	Date:		Sheet No.:	
Project No.:	AS SHOWN	Tender No.:	DR		
A1		3002750-WS-004		Rev	B