



- NOTES:**
1. ALL DIMENSIONS DENOTED BY * TO BE CONFIRMED ON SITE PRIOR TO FABRICATION
 2. ALL STEEL TO BE MIN 300 GRADE.
 3. ALL STEEL FRAME MEMBERS 150 PFC U.N.O
 4. CONTRACTOR TO DESIGN, MANUFACTURE, AND ERECT A DURABLE SIGN IN A VISIBLE LOCATION AT ENTRY TO THE VALVE PIT DECK THAT, SUBJECT TO APPROVAL OF THE SUPERINTENDENT, STATES THE FOLLOWING:
- "ALLOWED MAXIMUM LOAD ON THE STRUCTURE IS 5 kPa"
 5. ACCESS COVERS TO BE FABRICATED AND INSTALLED AS 2 SEPARATE PIECES.

DESIGN

No.	REVISION	DATE	ENG CHECKED	VERIFIED	DESIGN AUTH
B	ICON WATER RESUBMISSION	07.05.2024	A.L.	A.C.	
A	ICON WATER RESUBMISSION	30.11.2023	A.L.	A.C.	



Drawn: N.BROOKE-TAYLOR	Designed: M. HOSSEINI
Checked: A.CHANDRA	
Project Manager: T. VAN NIEKERK	
Contractor's Drawing No.: 3002750-WS-041	
Icon Water Consented:	
Icon Water Design Authority:	

WILLIAM HOVELL DRIVE DUPLICATION
ACCESS COVERS - HOT DIP GALVANISED STEEL
DROP IN FAME - DETAILS

Scale: AS SHOWN	Date:	Sheet No.:
Project No.: AS SHOWN	Tender No.: DR	
A1	3002750-WS-042	Rev B