

# BLOCK 6 SECTION 7

Building 1 (KFC)	352m <sup>2</sup>
---------------------	-------------------

Building	VA/m <sup>2</sup>	Watts	Max Demand(kVA)	Amps			Comments
				A	B	C	
Building 1 (Proposed KFC)	-	-	138.2	200	200	200	Existing supply. 200 A 3Ø KFC as per design brief.
External lighting	-	606	0.612	1	-	-	As per lighting design submitted for DA
<b>Total</b>				<b>201</b>	<b>200</b>	<b>200</b>	200A 3Ø supply