



DRIVEWAY 01
1:100@A1




DRIVEWAY 02
1:100@A1



DRIVEWAY 03
1:100@A1


LEGEND



HD2 DRIVEWAY

NOTES

1. REFER TO 10675-01-001 FOR GENERAL NOTES AND LEGEND



LOCALITY PLAN
NTS

DRIVEWAY NOTES

1. ALL CONCRETE SHALL BE GRADE 40 (F_c = 40MPa) AGGREGATE SIZE TO BE 20mm MAX.
2. DRIVEWAY SHALL BE 150mm MIN. THICK OR MATCH EXISTING AND REINFORCED WITH SL82 REO-MESH AT 50mm TOP COVER.
3. DRIVEWAY SHALL BE CONSTRUCTED ON DGB20 OF 75mm MIN. THICKNESS AND COMPACTED TO 95% MMDD SUBGRADE SHALL BE COMPACTED TO 90% MMDD.
4. BROOMED FINISH TO BE APPLIED TO THE CONCRETE SURFACE.
5. ALL CONCRETE TO BE CURED CONTINUOUSLY FOR THREE (3) DAYS AFTER PLACING.
6. EXPANSION JOINTS ARE TO BE PLACED AT ALL CONNECTIONS TO EXISTING SLABS OR STRUCTURES.
7. CONNECTION TO EXISTING DRIVEWAY IS TO BE SMOOTH AND HAVE AN EVEN CHANGE IN GRADE.
8. DRIVEWAYS ARE NOT TO BE CONSTRUCTED CLOSER THAN 1200mm TO ANY ENGINEERING SERVICE SUCH AS SUMPS, 1500mm TO STREETLIGHTS, MINI-PILLARS, SUBSTATIONS OR BUS STOPS/SHELTERS AND 3000mm TO TREES UNLESS NOTED OTHERWISE
9. FOOTPATH THROUGH DRIVEWAY TO BE 150mm THICK AND CONSTRUCTED AS PER DRIVEWAY NOTES.
10. SAW CUT AND BREAK OUT FOOTPATHS TO NEAREST JOINT BEYOND DRIVEWAY EDGE.

CLOUD REVISION	DESCRIPTION
B	ADDITIONAL DIMENSIONS ADDED. LANDSCAPE ELEMENTS UPDATED



REV.	DESCRIPTION	DRAWN	DESIGNED	VERIFIED	APPROVED	DATE
B	DA AMENDMENT	DY	JP	JP	AN	2026-03-06
A	FOR DA	DY	JP	JP	AN	2025-08-07

ARCHITECT / BUILDING DESIGNER	MATIER © MATIER3 PTY LIMITED ARCHITECT
DEVELOPER	
LAND OWNER:	

CLIENT	URBN — DG
--------	----------------------

INDESCO INDESCO PTY LTD www.indesco.com.au ABN: 37 006 581 066
--

PROJECT TITLE	PHILLIP SECTION 7 BLOCK 4
---------------	------------------------------

CLIENT	URBN-DG
DRAWING STATUS	FOR APPROVAL
SCALE	AS SHOWN
COORDINATE SYSTEM	MGA2020-55
DATUM	AHD
SHEET SIZE	A1
PROJECT NUMBER	10675-01

DRAWING TITLE	DRIVEWAY PLAN
DRAWING NUMBER	100
REVISION	B