



DRIVEWAY 01
 1:100@A1



DRIVEWAY 02
 1:100@A1




DRIVEWAY 03
 1:100@A1

DRIVEWAY NOTES

- ALL CONCRETE SHALL BE GRADE 40 (F'c = 40MPa) AGGREGATE SIZE TO BE 20mm MAX.
- DRIVEWAY SHALL BE 150mm MIN. THICK OR MATCH EXISTING AND REINFORCED WITH SL82 REO-MESH AT 50mm TOP COVER.
- DRIVEWAY SHALL BE CONSTRUCTED ON DGB20 OF 75mm MIN. THICKNESS AND COMPACTED TO 95% MMDD SUBGRADE SHALL BE COMPACTED TO 90% MMDD.
- BROOMED FINISH TO BE APPLIED TO THE CONCRETE SURFACE.
- ALL CONCRETE TO BE CURED CONTINUOUSLY FOR THREE (3) DAYS AFTER PLACING.
- EXPANSION JOINTS ARE TO BE PLACED AT ALL CONNECTIONS TO EXISTING SLABS OR STRUCTURES.
- CONNECTION TO EXISTING DRIVEWAY IS TO BE SMOOTH AND HAVE AN EVEN CHANGE IN GRADE.
- DRIVEWAYS ARE NOT TO BE CONSTRUCTED CLOSER THAN 1200mm TO ANY ENGINEERING SERVICE SUCH AS SUMPS, 1500mm TO STREETLIGHTS, MINI-PILLARS, SUBSTATIONS OR BUS STOPS/SHELTERS AND 3000mm TO TREES UNLESS NOTED OTHERWISE
- FOOTPATH THROUGH DRIVEWAY TO BE 150mm THICK AND CONSTRUCTED AS PER DRIVEWAY NOTES.
- SAW CUT AND BREAK OUT FOOTPATHS TO NEAREST JOINT BEYOND DRIVEWAY EDGE.


LEGEND




HD2 DRIVEWAY

NOTES

- REFER TO 10675-01-001 FOR GENERAL NOTES AND LEGEND



LOCALITY PLAN
 NTS



REV.	DESCRIPTION	DRAWN	DESIGNED	VERIFIED	APPROVED	DATE
A	FOR DA	DY	JP	JP	AN	2025.08.07

ARCHITECT / BUILDING DESIGNER	MATIER © MATIER3 PTY LIMITED ARCHITECTS
DEVELOPER	
LAND OWNER:	

CLIENT	URBN — DG
--------	----------------------------

INDESCO INDESCO PTY LTD www.indesco.com.au ABN: 37 008 581 066
--

PROJECT TITLE	PHILLIP SECTION 7 BLOCK 4
---------------	--

CLIENT	URBN-DG
DRAWING STATUS	FOR APPROVAL
SCALE	AS SHOWN
COORDINATE SYSTEM	MGA2020-55
DATUM	AHD
SHEET SIZE	A1
PROJECT NUMBER	10675-01

DRAWING TITLE	DRIVEWAY PLAN
DRAWING NUMBER	100
REVISION	A