



THE PROPOSED LIGHTING DESIGN MEETS THE REQUIREMENTS FOR CATEGORY PP3 & PR3 IN ACCORDANCE WITH AS/NZ 1158.3.1:2020 LIGHTING SUBCATEGORY FOR PEDESTRIAN AND CYCLE PATHS AND ROAD RESERVES IN LOCAL AREAS, AS WELL AS AS/NZS 4282:2023 FOR OBTRUSIVE EFFECT OF OUTDOOR LIGHTING.

ELECTRICAL CONTRACTOR



Heyday Group

192 Gladstone Street  
Fyshwick ACT 2609  
Australia  
Telephone (02) 6280 0400  
Facsimile (02) 6280 0411  
<http://www.heyday5.com.au>

Issue	Date	By	Chkd	Appd
01	11.07.25	KD	DL	IB

FOR DA

ARCHITECT

# METIER

**METIER**  
T +61 3 9420 4000  
METIER3.com.au

LANDSCAPE ARCHITECT

# OCULUS

**OCULUS**  
australia@oculus.info

MANAGING CONTRACTOR

U R B N  
— D G

**URBN DG**  
Telephone +61 417 428 071  
hello@urbandg.com.au

PROJECT

WODEN VILLAGE  
BLOCK 4, SECTION 7  
PHILLIP, ACT

HEYDAY PROJECT NUMBER

CEC-00000

GRAPHIC SCALE



SCALE

NTS @ A1 DO NOT SCALE

## DRAWING

ELECTRICAL SERVICES  
EXTERNAL LIGHTING  
LAYOUT  
GROUND LEVEL

FOR DA

DRAWING NUMBER  
E-DA-05

04